

# EC-TYPE EXAMINATION CERTIFICATE (MODULE B)

Application of: Directive 2014/90/EU of 23 July 2014 on marine equipment (MED), issued as "Forskrift om Skipsutstyr" by the Norwegian Maritime Authority. This Certificate is issued by DNV GL AS under the authority of the Government of Norway.

## This is to certify:

**That the Penetrations through "A" class divisions: electric cable transits**

with type designation(s)

**A-0 Class single cable penetrations through square sleeve with GPG Marine Mortar sealing system**

Issued to

**Firesafe Energy AS**  
**Lørenskog, Norway**

is found to comply with the requirements in the following Regulations/Standards:

Regulation **(EU) 2018/773,**


**item No. MED/3.26a. SOLAS 74 as amended, Regulation II-2/9 and IMO 2010 FTP Code**

Further details of the equipment and conditions for certification are given overleaf.

This Certificate is valid until **2024-04-25.**

Issued at **Høvik** on **2019-04-26**

DNV GL local station:  
**Oslo Maritime and CAP**



for **DNV GL AS**

Approval Engineer:  
**Tessa Bieber**

Notified Body  
No.: **0575**

**Roald Vårheim**  
**Head of Notified Body**

A U.S. Coast Guard approval number will be assigned to the equipment when the production module has been completed and will appear on the production module certificate (module D, E or F), as allowed by the "Agreement between the United States of America and the EEA EFTA states on the mutual recognition of Certificates of Conformity for Marine Equipment" signed 17 October 2005.

The mark of conformity may only be affixed to the above type approved equipment and a Manufacturer's Declaration of Conformity issued when the production-surveillance module (D, E or F) of Annex B of the MED is fully complied with and controlled by a written inspection agreement with a Notified Body. The product liability rests with the manufacturer or his representative in accordance with Directive 2014/90/EU.

This certificate is valid for equipment, which is conform to the approved type. The manufacturer shall inform DNV GL AS of any changes to the approved equipment. This certificate remains valid unless suspended, withdrawn, recalled or cancelled.

Should the specified regulations or standards be amended during the validity of this certificate, the product is to be re-approved before being placed on board a vessel to which the amended regulations or standards apply.



## Product description

'A-0 Class single cable penetrations through square sleeve with GPG Marine Mortar sealing system'

Penetration composed of a 10 mm thick square steel sleeve symmetrically welded to steel bulkhead/deck.

The deck and bulkhead penetrations are sealed with GPG Marine Mortar (GPGM Mortar) which is a powder mainly consisting of plaster, perlite and glass fibre. To be mixed with water to obtain desired consistency (see data sheet for correct mixing ration for application). The density of GPGM Mortar is 701 kg/m<sup>3</sup>.

See below table for penetration details:

Name	Sleeve length [mm]	Outer Sleeve Dimensions (w x l) [mm]	Filling	Use	Insulation	Remarks
CG43 CG45	60-90	116 x 116	Single cable Ø52 mm	deck	None	20 mm additional GPGM Mortar on top
CG72 CG73	60-90	116 x 116	Single cable Ø52 mm	bulkhead	None	20 mm additional GPGM Mortar on both sides

For further details see drawings in the test reports listed under Type Examination documentation below.

## Application/Limitation

Approved for use as single cable penetration system in A-0 steel bulkheads/decks. Other applications are subject to case-by-case approval.

Watertightness and gastightness is not covered in this certificate.

Each product is to be supplied with its manual for installation and maintenance.

## Type Examination documentation

Test report Nos.:

- 150072-06A (A-0, steel deck) dated 2017-12-18
- 150072-08A (A-0, steel bulkhead) dated 2018-09-14

Both from RISE, Trondheim, Norway.

## Tests carried out

Tested in according to IMO 2010 FTP Code part 3.

## Marking of product

The product or packing is to be marked with name and address of manufacturer, type designation, fire-technical rating, MED Mark of Conformity and USCG approval number if applicable (see first page).