



DECLARATION OF PERFORMANCE (DoP)

in accordance with Annex III to Regulation (EU) no. 305/2011
(Construction Products Regulation)

FIRESAFE / FSW

DoP no.: FS/PP/FSW – 30.07.2025

1. Unique identification of the product type:

FIRESAFE / FSW Firestop Wrap for Penetration Seals.

2. Type, batch or serial number or any other element allowing identification of the construction product as required pursuant to Article 11(4): See batch number on product packaging or scan the QR code on the packaging for detailed information.

3. Intended use or uses of the construction product in accordance with the applicable harmonised technical specification:

3.1 The intended use of FIRESAFE / FSW is the maintenance of the fire resistance performance of plaster walls, masonry walls and floors for the fireproofing of various pipe penetrations made of plastic, metal and aluminium, composite pipes with and without combustible insulation. When using FIRESAFE / FSW in combination with FIRESAFE / FSA Firestop Acrylic or FIRESAFE / FSB Firestop Board System or Class A1 gypsum-based fireproofing compounds, it provides a fire- and smoke-proof seal against adjoining rooms as contained in **ETA 25/0234**.

3.2 The use category for the FIRESAFE / FSW system is indoor and outdoor use.

Temperatures below 0 °C with exposure to UV (occasionally), but not with exposure to rain (TR 024, type Y₁).

3.3 The provisions contained in the Declaration of Performance are based on an assumed service life of FIRESAFE / FSW of 25 years: provided that all conditions in the manufacturer's data sheet and instructions for packaging, transportation, storage, installation, use and repair have been met. The indications given to the end user cannot be interpreted as a guarantee provided by the manufacturer, but must only be considered as an aid to choosing the right products in relation to the expected financially reasonable service life of the solution.

4. Name, registered trade name or registered trade mark and contact address of the manufacturer as required pursuant to Article 11(5):

Firesafe AS

Robsrudskogen 15, 1470 Lørenskog

Postboks 6411 Etterstad, 0605 OSLO

Telephone: +47 22 72 20 20

www.firesafe.no

5. Where applicable, name and contact address of the authorised representative whose mandate covers the tasks specified in Article 12(2):
Not relevant.

6. System or systems of assessment and verification of constancy of performance of the construction product as set out in Annex V:
AVCP System 1.

7. In case of the Declaration of Performance concerning a construction product covered by a harmonised standard:
Not relevant.

8. In case of the Declaration of Performance concerning a construction product for which a European Technical Assessment has been issued:

This Declaration of Performance has been prepared in accordance with the guidelines contained in EAD 350454-00-1104.

ETA 25/0234 prepared by UL International BV, Notified Body 2821, Certificate of Performance no. 2821-CPR-0345.

9. Declared performance:

Essential characteristics	Performance	Harmonised technical specification
Reaction to fire	C-s1,d0	EN 13501-1
Resistance to fire	ETA 25/0234 Penetration Seals	EN 13501-2
Air permeability	NPD	EN 1026
Water permeability	NPD	EAD 350454-00-1104, Annex C
Release of hazardous substances	IA1, S/W2	EOTA TR 034
Mechanical resistance and stability	NPD	EOTA TR 001
Resistance to shock/movement	NPD	EOTA TR 001
Airborne sound insulation	NPD	EN 10140-2
Impact sound insulation	NPD	EN 10140-3
Thermal properties	NPD	EN 12664, EN 12667 or EN 12939
Water vapour permeability	NPD	EN ISO 12572, EN 12086
Durability and usability	Y ₁	EOTA TR 024

NPD = No Performance Determined.

10. The performance of the product identified in points 1 and 2 is in conformity with the performance in point 9.
This Declaration of Performance is issued under the sole responsibility of the manufacturer identified in point 4.

Signed for and on behalf of Firesafe:

Pål Paulsen

Technical Department – Product Manager, Firestopping Products

FIRESAFE AS

